

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7272-1597:104

Page 1 of 1

CATEGORY: Photoelectric Smoke Detector

LISTEE: TEPG – US, 91 Technology Drive, Westminster, MA 01441-0001
Contact: Paul Mattern (978) 731-8542 FAX (978) 731-8881

DESIGN: Models 430631, *T360-9050, 430634, and *T360-9051 analog photoelectric type smoke detectors. All units are intended for use with Models 430636, 430637, 430638, 430640, *T360-9950, *-9951, *-9952, or *-9953 detector bases (CSFM Listing No. 7300-1597:103). Models 430634 and *T360-9051 employ an integral supplemental heat sensor (135° F fixed temperature and 120° F rate of rise). This heat sensor is intended for use as a supplemental device to the smoke detector and is not intended for use in lieu of required heat detectors. Refer to listee's printed data sheet for additional detailed product description and operational considerations

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating, and UL label.

APPROVAL: Listed as photoelectric smoke detectors for use with *listee's separately listed *Model T310-9301 series (CSFM Listing No. 7170-1597:116), Ansul Model Autopulse Z-28(430532) & (430539) (CSFM Listing No. 7170-0595:114) and Pyro-Chem Model Triton RPA(551454) & (551461) (CSFM Listing No. 7170-1565:104) fire alarm control units. Refer to listee's Installation Instruction Manual for details.

XLF: 7272-0026:218

*Rev. 05-11-04



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **MAY 11, 2004**

*Listing Expires **June 30, 2004***

Authorized By: **DIANE K. AREND, Senior Deputy
Program Manager**